

Peralta Energy
Oakland, CA
510.459.0827



Report version: 1.0

Author: Ben Thompson

Report prepared for:

Berkeley Student Cooperative

Property name & address:

Casa Zimbabwe, Central Kitchen & Central Office, 2424 Ridge Rd., Berkeley CA 94709

Property type:

Residence hall, office and warehouse with basement garage.



Executive Summary:

The property presents a significant opportunity to reduce energy use and operating costs. Total annual electric and gas savings is projected to be on the order of \$17,000. Total project cost is projected to be \$70 - \$100,000 not counting new windows, for a simple payback of 4.1 to 5.8 years. Maintenance savings (eg. changing fluorescent tube lights) is not included.

The space heating and solar hot water systems need to be re-commissioned. Neither the space heating nor the solar hot water systems are functioning properly. Solar hot water system is losing heat to the air at night due to continuously operating circulation pump. The space heating system fails to deliver heat when desired, and delivers heat when it is not desired. Ventilation fans run continuously at high speed. Walk-in cooler and freezer fan operation is inefficient. CZ kitchen exhaust fans run continuously.

Space heating: The boilers, air supply fans and hot water circulator pumps run continuously, even on warm days, rather than responding to demand. The pneumatic control system is obsolete and should be replaced with a digital control system with a web based interface.

Solar hot water: At a minimum, this system needs to be re-commissioned with new sensors and controllers and a web based interface to monitor performance. Some of the collectors should to be replaced as well.

Lighting also presents an opportunity for savings. A photocell is recommended to control loading dock lights. Occupant sensor for crafts room. Improved sensor for lounge. Replace all 'T-8' linear fluorescent lamps with LED.

Existing Conditions

<p>Annual Energy Use: Facility site energy use intensity: 111.4 kBTU/sq ft. Electrical use: 347,451 kWh/yr. Gas use: 33,314 therms/yr.</p>	<p>Annual Energy Costs: Electricity: \$32,800. Average cost/kWh: \$0.09/kWh Gas: \$8,274. Average cost/therm: \$0.25/therm</p>
---	---

CO₂ emissions: 630,000 pounds CO₂/year


Greenhouse gas emissions are calculated at CPUC ClimateSmart rates of 0.524 lbs. CO₂/kilowatt-hour and 13.446 lbs. CO₂/therm of gas.

Electricity usage for CZ, CK and CO are shown in the tables below (2 electric meters).




Peralta Energy - Energy Audit Report - CZ-CK-CO

Summer time gas use was significantly lower six years ago, as shown below.



Summer time gas use since 2008 has been much higher.



Comparison of gas use at Cloyne and CZ-CK-CO, which are similar sized facilities.


Cloyne annual therms/sq ft	0.30	Therms/yr	11706
CZ annual therms/sq ft	0.82	Therms/yr	33314

Mechanical equipment:

- Heating: Two Weil-McLean boilers provide heat for space and domestic hot water. Office, central kitchen and common areas of dormitory have central forced air with three pre-heat coils and fifteen zone level re-heat coils. Controls are pneumatic. Dorm bedrooms have baseboard convectors (radiators) controlled by room thermostats.
- Water heating is provided by a solar thermal system with back-up provided by a heat exchanger loop from the boilers.
- Mechanical ventilation is provided by several supply and exhaust fans. Three of the original exhaust fans that were part of the central kitchen have been removed.

Solar hot water system:

Measured temperatures on the risers (pipes) leading to and from the solar collectors remains over 70 degrees at night. The circulator pump runs continuously. The hot water system is losing heat at night to the outdoors. The temperature split (difference) between the inlet pipe (lower peaks) and the collector outlet (higher peaks) is about 20 degrees during the day. This is an expected (design) value.



Lighting:

Almost all of the lighting in the facility is T-8 fluorescent tubes. Occupancy sensors control lighting in bathrooms and several other locations.

Energy Retrofit Recommendations:

Low cost measures:

	Existing annual kWh	New annual kWh	Annual kWh savings	Cost	Annual \$ savings	ROI yrs
Exhaust fan controller (MeLink) – CZ kitchen	5088	509	4579	\$4,000.00	\$457.90	8.74
Loading dock photocell	3504	2000	1504	\$500.00	\$150.40	3.32
Crafts room occ sensor	1728	576	1152	\$200.00	\$115.20	1.74
CK and CZ coolers	49112	28238	20874	\$5,189.00	\$2,087.40	2.49
Rooftop condensing unit CZ cooler	6665	3500	3165	\$2,000.00	\$316.50	6.32
Totals	66097	34823	31274	\$11,889.00	\$3,127.40	4.52

Lighting												
	fixtures	watts/fix	watts	annual hours	annual kWh	lamps	new LED watts	annual kWh savings	Cost @ \$25ea	Annual \$ savings	ROI yrs	
CO lights	25	64	1600	2000	3200	50	1000	1200	\$1,250	\$120	10.42	
CK lights	40	64	2560	2000	5120	80	1600	1920	\$2,000	\$192	10.42	
CK dock lights	10	64	640	5000	3200	20	400	1200	\$500	\$120	4.17	
CZ lights												
Arts & Crafts	6	64	384	1500	576	12	240	216	\$300	\$22	13.89	
Entryway	6	64	384	6000	2304	12	240	864	\$300	\$86	3.47	
Garage	26	64	1664	8760	14577	52	1040	5466	\$1,300	\$547	2.38	
Corridors	120	32	3840	8760	33638	80	1600	19622	\$2,000	\$1,962	1.02	
Kitchen	8	64	512	6600	3379	16	320	1267	\$400	\$127	3.16	
Lighting Totals	241	480	11584	40620	65994	322	6440	31756	\$8,050	\$3,176	6.1	

Peralta Energy - Energy Audit Report - CZ-CK-CO

Capitol intensive measures:

The central heating system should be re-commissioned with digital controls and actuators, demand responsive variable frequency drives on the central supply and exhaust fans, outdoor reset sensors and new zone level thermostats. Cost will be \$50,000 to \$80,000. Electrical usage and savings is shown in the table below. Post-refit duty cycle (on %) of fans and pumps is estimated.

Pumps and fans	Serves	On %	HP	Amps	Volts	Watts	PF	kWh/yr	Assumed New on %	New kWh/yr	Savings
HVAC system											
Air compressor		33%		2	220	440	0.66	839	0%	0	\$84
Supply fan 1 – boiler room	general	100%	5	16	220	3520	0.66	20351	50%	10176	\$1,018
Supply fan 2 - over cooler	dorm	100%	2	6	220	1320	0.66	7632	50%	3816	\$382
Supply fan 3 - over cooler	kitchen	100%	7.5	6	220	5550	1	48618	50%	24309	\$2,431
Exhaust fan 1 – parts room	general	100%	2	6	220	1320	0.66	7632	50%	3816	\$382
Exhaust fan 4	women's dorm	100%	0.33	1.5	110	244.2	1	2139	100%	2139	\$0
Exhaust fan 5	men's dorm	100%	0.33	1.5	110	244.2	1	2139	100%	2139	\$0
Exhaust fan 8	garage exhaust	0%	2	10	220	1480	0.66		0%	0	\$0
Exhaust fan 9	unit ventilation	100%	0.75	3	110	555	1	4862	50%	2431	\$243
main hot water circ pump	building	100%				950	0.66	5493	20%	1099	\$439
main hot water circ pump	building	100%				950	0.66	5493	20%	1099	\$439
										0	
										0	
DHW											
circ pump near tank		94%				410	0.66	2228	70%	1659	\$57
small DHW circ pump		100%				215	0.66	1243	70%	870	\$37
solar circ pump		100%				215	0.66	1243	30%	373	\$87
Totals								109912		53925	\$5,599
Note:	Exhaust fans 2, 6 & 7 were removed when CK was decommissioned. Garage exhaust is currently turned off										

Potential gas savings of \$5,000 is estimated by comparing the current usage at Cloyne Ct. and Casa Zimbabwe. Existing Cloyne gas usage is reasonably efficient.

Natural gas						
CZ annual therms/sq ft		0.82		Therms/yr	33314	\$/yr \$8,274
Cloyne annual therms/sq ft		0.30		Therms/yr	11706	\$/yr \$2,892
Difference		0.52			21608	\$5,382

Other recommended measures:

- Replace bedroom windows as budget allows.

Maintenance recommendations:

Supply air screens: Screens are located in the condenser 'room' over the walk-in coolers, on the wall next to the driveway just off the street, and at the patio in front of the central office.

Check all dorm room heating control valves and air vents annually.

Create an operations and maintenance manual for the boilers and central heating system.

Walk in cooler evaporator fans present a significant opportunity for savings by installing high efficiency motors and fan controllers.



Condenser fan motors should also be replaced.



This large exhaust fan removes air from the condenser room over the coolers. Install a thermostatically controlled variable frequency drive to reduce motor RPM. ('Demand control ventilation.')




This rooftop condensing unit is for the CZ kitchen cooler. It is a 20 years old SEER 8 unit. Replace with a new SEER 16.



Maintenance: Clogged screens restrict air flow. Clean screens in condenser room regularly.



Pneumatic controls on the heating system are obsolete, difficult to maintain, and provide no real time system monitoring. Replace with digital controls.



Air compressor serves pneumatic controls. It goes away when pneumatic controls are replaced.



Larger ventilation fan motors run at continuous high speed. Install VFD drives to regulate speed and set demand schedules.



CZ kitchen exhaust fans run continuously. Install a Me-Link automatic control system like the one at Cloyne.



Replace fluerescent lamps with LEDs.



Including cooler lighting.




Air vents on bedroom radiators must be checked for failure.



Many of the thermostatically controlled valves in the bedrooms have failed. Some are stuck open. Some stuck closed.



Operations: We recommend creating an operations manual for the heating system. These instructions are hard to read.



Instructions written on the wall.



Outdoor reset T-stat appears to do nothing.



Replacement of dorm room windows is recommended, although payback is long term.




This type of ceiling mounted occupant sensor is effective for controlling lighting (CK break room). Wall mounted units in CZ dining and lounge are less effective.



Some of the solar collectors may have to be replaced. First step is to get existing system operating correctly with real time monitoring.



Cooler Retrofit estimate provided by Frigitek.

 (877) 523-6934	Frigitek[®] ECMotor Savings Summary				Summary Sheet 1	
	=====					
Rev Date	Date -	March 7, 2014				
12/23/13	Customer -	Peralta Energy for Berkeley Student Co-Op				
	Address -					
	City, St, ZIP -	Berkeley, CA				
Sales Rep -	Contact -	Ben Thompson				
Joe Simko	Phone -	510-459-0827				
=====						
*** Overall Summary ***			Summary Sheets -			2
	Total Cost -	\$6,858.94		ROI -	39.43	Mo
	Total Cost w/ Rebate -	\$5,188.97		ROI w/ Rebate -	29.83	Mo
	Total Dollar Savings -	\$173.95	/Mo	\$2,087.46	/Yr	
	Total kWh Savings -	1,739.5	kWh/Mo	20,874.6	kWh/Yr	
	CO₂ Reduction -	11,272.3	Lbs/Yr	CO₂ Factor -	0.54	
=====						